

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 717

Date 11/04/2026

It is certified that an inspection team headed
by E. Engineer P.H. Division Buxar (Name of officer with designation)
from P.H.E.D. Buxar (Name of Department/ office)
Inspected the Central Public School.

Dahisar, Buxar.
(Name and Address of the School) onand found that
the Central Public School (Name of school) has safe
drinking water facilities for the student and members of staff of the
institution and is maintain the hygienic sanitation condition in the school
building & the campus as per norms prescribed by the
Central/State/U.T.Govt.

The above valid for a period of Six month only.

Signature with seal:.....

Name Rahul Kumar.

Designation: Executive Engineer

To

Principal,
Central Public School,
Dahisar, Buxar.
(Name & Address of institution)

Government of Bihar
Public Health Engineering Department
Water Quality Test Report
Division Name: Buxar


Sample Collected by :- School Staff, Avdhesh kr. Chaubey.


Date: 09/04/2026

Sl.No	Block	Panchayat	Location	pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	As	Total CoH.	Remarks
1	Buxar	Dahiwar	Central Public School,	7.4	<1	522	339	182	48	32.2	60	142	0.2	BDL	18	0.2	BDL	Negative	SAFE
UNIT					NTU	μmho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		
Desirable Limit*				6.5-8.5	1		500	200	75	30	250	200	0.3	45	200	1	0.01		
max.permissible limit				NR	5		2000	600	200	100	1000	600	1.0	NR	400	1.5	NR		

* BDL - Below detection limit.

* NR - Not relaxation.


Chemist
P.H. Division, Buxar


Executive Engineer
P.H. Division, Buxar